

基隆市天外天垃圾資源回收(焚化)廠
廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10601	48.6	53.2	47.1	46.8	48.0	54.8	53.4	49.8
10602	47.9	54.4	54.8	48.5	56.4	57.1	48.1	46.8
10603	48.4	55.5	52.1	46.2	52.0	54.2	48.5	47.1
10604	53.7	50.4	50.9	50.3	52.0	50.0	48.9	46.2
10605	49.9	52.6	52.6	50.8	51.7	54.5	55.8	53.2
10606	58.1	58.3	56.2	53.5	53.3	52.1	53.1	52.7
10607	51.0	56.0	52.0	47.5	52.1	53.7	48.0	48.2
10608	48.7	55.2	50.6	49.3	49.4	49.9	47.6	45.5
10609	51.0	54.3	53.8	51.4	50.3	52.6	49.1	48.1
10610	57.7	64.1	53.2	51.8	50.1	52.5	52.4	51.2
10611	51.6	59.9	52.1	50.9	50.5	49.9	51.4	49.3
10612	46.2	50.1	49.6	46.8	50.2	51.3	49.5	50.7