



基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10501	51.1	52.6	50.6	49.5	50.6	50.7	51.5	52.5
10502	52.3	51.0	50.5	47.7	54.2	58.2	53.9	50.1
10503	55.5	58.3	57.4	54.6	50.9	53.0	51.1	50.4
10504	54.5	55.8	47.9	49.2	50.1	52.2	53.8	52.2
10505	53.3	52.0	52.6	48.5	48.7	49.6	48.1	48.2
10506	58.3	54.3	50.7	51.5	54.1	53.9	54.5	52.8
10507	54.5	54.2	53.1	54.3	58.3	50.7	51.7	51.9
10508	53.8	57.1	55.6	53.7	51.6	56.2	50.8	51.1
10509	45.4	51.5	47.4	47.2	48.2	48.6	49.7	48.6
10510	54	53	50.9	52.4	52	49.8	54.4	53.1
10511	48.5	50.1	52.4	49.5	48.4	51.0	51.2	50.9
10512	49.3	54.7	51.0	48.2	49.0	50.8	51.9	47.3