



基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10401	54.5	53.8	51.1	50.2	47.9	54.4	51.2	50.4
10402	50.5	50.4	47.8	47.8	49.5	54.2	49.5	49.3
10403	58.8	62.6	55.5	48.3	54.7	57.8	49.1	46.8
10404	56.5	61.1	60.4	54.2	57.1	56.9	56.6	54.2
10405	53.2	57.2	50.6	49.7	54.7	55.0	50.6	50.0
10406	54.6	57.2	47.7	46.7	55.7	56.2	51.1	49.9
10407	52.3	51.0	50.3	47.7	54.2	58.2	53.8	50.1
10408	51.3	62.7	61.0	54.6	50.4	48.5	48.7	49.3
10409	50.8	54.7	57.0	53.4	56.3	57.0	58.8	54.9
10410	53.8	52.2	51.1	52.6	51.2	49.6	52.9	49.2
10411	54.1	56.1	54.7	54.7	53.2	53.4	52.9	53.7
10412	49.1	54.3	49.6	49.5	49.4	50.3	48.7	47.3