

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位: dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值	65	70	65	55	65	70	65	55
10201	62.6	58.2	58.2	53.3	60.7	60.7	56.5	55.0
10202	50.3	48.2	57.3	47.5	56.0	53.9	51.6	53.0
10203	61.0	62.8	58.8	51.1	58.1	62.3	59.3	51.1
10204	48.7	53.8	47.6	47.4	47.7	51.8	55.3	51.5
10205	54.0	50.2	46.7	46.9	53.8	49.1	52.0	44.8
10206	56.3	60.8	54.0	50.2	55.5	63.0	54.9	53.4
10207	52.8	55.7	48.9	47.5	56.3	60.9	54.4	51.7
10208	49.4	55.5	53.7	52.3	48.3	52.4	52.7	49.0
10209	54.8	52.6	51.5	50.2	52.7	53.4	53.9	50.2
10210	58.5	58.6	61.4	54.8	54.9	61.0	57.1	54.4
10211	50.8	51.0	53.2	50.6	50.5	50.6	52.4	49.8
10212	55.6	63.4	61.1	53.2	53.2	60.0	55.9	52.4