



基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
9504	54.0	55.0	54.1	47.4	56.1	52.8	52.6	48.8
9505	48.2	57.5	61.6	60.1	50.9	53.6	54.4	55.5
9506	54.0	59.9	54.2	51.6	54.3	61.2	52.0	52.2
9507	55.0	53.5	54.9	52.2	54.1	53.6	52.6	51.9
9508	55.9	62.3	57.1	54.6	53.1	61.8	55.4	52.0
9509	51.0	55.8	54.0	52.7	50.9	56.2	53.7	52.6
9510	49.7	54.7	55.1	52.7	54.1	53.8	52.8	52.3
9511	49.6	53.8	53.6	51.6	49.3	54.4	55.7	51.9
9512	54.0	56.7	54.1	52.6	53.2	53.8	53.3	53.2