

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH —
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10701	2018/01/04	上旬	2.2	2.9	7.7	22.9	7.4
	2018/01/17	下旬	2.0	1.5	2.6	21.2	7.5
10702	2018/02/01	上旬	1.4	ND	4.3	20.3	7.4
	2018/02/21	下旬	2.6	ND	2.7	20.5	7.5
10703	2018/03/01	上旬	2.9	ND	1.5	22.8	7.2
	2018/03/15	下旬	1.9	ND	2.2	22.6	7.4
10704	2018/04/02	上旬	2.0	ND	2.9	25.5	7.3
	2018/04/16	下旬	3.3	2.4	6.6	25.4	7.5
10705	2018/05/03	上旬	3.4	3.6	14.6	27.2	7.6
	2018/05/16	下旬	2.4	2.0	10.4	28.8	7.0
10706	2018/06/05	上旬	ND	ND	4.4	30.7	7.4
	2018/06/14	下旬	1.8	1.7	3.7	30.3	7.5
10707	2018/07/02	上旬	1.6	ND	2.2	31.9	7.4
	2018/07/19	下旬	1.0	ND	2.2	31.1	6.8
10708	2018/08/02	上旬	2.2	ND	3.5	33.3	7.4
	2018/08/16	下旬	ND	ND	3.4	31.9	7.7
10709	2018/09/03	上旬	ND	ND	2.2	30.5	8.0
	2018/09/18	下旬	1.8	2.1	5.9	31.6	6.8
10710	2018/10/01	上旬	3.0	ND	3.7	28.6	7.0
	2018/10/15	下旬	1.2	4.2	7.6	27.0	6.4
10711	2018/11/01	上旬	ND	3.0	4.0	24.7	6.6
	2018/11/15	下旬	4.0	1.3	2.6	25.0	6.9
10712	2018/12/03	上旬	1.8	1.8	3.8	25.8	7.2
	2018/12/17	下旬	ND	1.5	5.5	22.4	7.0