

基隆市天外天垃圾資源回收(焚化)廠
廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10701	44.2	51.3	49.1	53.8	49.0	52.4	53.5	48.4
10702	45.5	44.9	45.7	45.6	46.4	47.7	49.6	46.8
10703	45.1	44.4	45.1	45.3	45.7	47.1	48.9	46.1
10704	53.7	52.8	50.3	51.3	49.3	52.3	48.8	47.0
10705	50.9	47.4	52.7	51.2	48.4	49.8	49.4	48.0
10706	51.1	52.0	44.8	45.2	49.5	51.8	48.6	46.2
10707	56.6	52.0	58.3	50.0	54.0	48.0	48.0	47.8
10708	53.5	55.8	55.5	53.0	50.3	53.2	55.2	53.7
10709	46.5	46.2	46.1	46.6	50.0	48.7	50.6	49.4
10710	49.8	48.9	49.6	47.4	51.3	52.8	48.1	45.4
10711	47.4	47.5	47.8	49.1	49.6	47.8	50.6	50.4
10712	46.8	46.7	47.6	47.6	46.6	46.6	46.5	47.3