

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	3	2	-	-
9504	2006/05/05	上旬	5.9	5.1	38.1	—	7.4
	2006/05/11	下旬	6.2	4.7	37	—	7.7
9505	2006/05/12	上旬	6.4	4.4	36.7	—	7.6
	2006/05/17	下旬	14.8	17.6	49.6	—	7.7
9506	2006/06/09	上旬	17.6	13.2	32.2	—	7.9
	2006/06/20	下旬	9.9	9.2	32	—	7.6
9507	2006/07/03	上旬	9.7	ND	6.9	38.2	8.2
	2006/07/19	下旬	16	ND	16.4	36.9	7.7
9508	2006/08/03	上旬	14.9	3.9	16.1	37.8	8.1
	2006/08/15	下旬	18.6	ND	17.1	36.8	8.6
9509	2006/09/01	上旬	3.3	ND	4.5	31.7	7.9
	2006/09/15	下旬	18.4	6.6	28.2	35.5	7.9
9510	2006/10/02	上旬	5.3	ND	9.3	31.3	7.2
	2006/10/16	下旬	12.1	12.5	31.9	32.8	7.9
9511	2006/11/02	上旬	13.6	3	12.3	30.4	7.9
	2006/11/14	下旬	3.2	ND	5.8	30.7	7.9
9512	2006/12/05	上旬	17.6	ND	11.6	29.4	7.8
	2006/12/15	下旬	17.4	ND	17.2	30.4	7.8