

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	3	2	-	-
9601	2007/01/03	上旬	8.2	ND	6.8	30.2	7.7
	2007/01/16	下旬	7.8	ND	3.3	30.2	7.7
9602	2007/02/01	上旬	ND	ND	2.4	31	7.6
	2007/02/09	下旬	4.9	ND	11.2	30.4	7.6
9603	2007/03/01	上旬	3.4	ND	5.7	30.1	7.5
	2007/03/19	下旬	2.3	ND	ND	30.2	7.7
9604	2007/04/02	上旬	2	ND	6.5	30.1	7.9
	2007/04/17	下旬	3.4	ND	3.6	29.3	7.5
9605	2007/05/02	上旬	1.2	ND	3.7	29.8	7.6
	2007/05/14	下旬	1.1	ND	ND	29.1	7.5
9606	2007/06/01	上旬	1.8	ND	4.5	29.7	7.9
	2007/06/14	下旬	1.6	ND	ND	29.4	7.5
9607	2007/07/02	上旬	1.6	ND	4.9	30.3	7.4
	2007/07/10	下旬	1.2	ND	3.5	32	7.7
9608	2007/08/02	上旬	1	ND	3.1	32.4	7.7
	2007/08/16	下旬	ND	ND	ND	30.8	7.5
9609	2007/09/06	上旬	3	ND	ND	30.4	7.8
	2007/09/17	下旬	ND	ND	2.3	29.2	7.7
9610	2007/10/01	上旬	2.2	ND	3.4	29.4	7.5
	2007/10/15	下旬	1.4	ND	ND	27	7.6
9611	2007/11/02	上旬	2.8	ND	5.4	24.1	6.7
	2007/11/19	下旬	ND	ND	ND	25.3	7.5
9612	2007/12/03	上旬	ND	ND	ND	24.1	7.2
	2007/12/14	下旬	1	ND	ND	23.1	7.4