

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體	生化需氧量	化學需氧量	溫度	pH
			SS mg/L	BOD mg/L	COD mg/L	℃	—
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10301	2014/01/02	上旬	7.4	ND	15.1	21.6	6.9
	2014/01/13	下旬	12.4	2.0	9.0	21.3	6.7
10302	2014/02/06	上旬	2.0	ND	2.6	21.9	7.0
	201402/17	下旬	7.7	ND	4.7	20.6	7.0
10303	2014/03/06	上旬	11.0	ND	6.6	21.7	6.8
	2014/03/24	下旬	6.4	ND	ND	23.3	7.0
10304	2014/04/03	上旬	ND	ND	1.6	23.2	7.2
	2014/04/21	下旬	4.0	ND	1.6	26.0	7.1
10305	2014/05/02	上旬	5.4	ND	6.0	26.6	7.2
	2014/05/19	下旬	4.2	ND	4.5	26.2	7.7
10306	2014/06/05	上旬	ND	ND	2.2	26.5	7.6
	2014/06/16	下旬	1.1	ND	2.4	27.0	7.4
10307	2014/07/02	上旬	ND	ND	3.6	29.2	7.4
	2014/07/16	下旬	8.3	1.1	5.0	31.5	7.0
10308	2014/08/04	上旬	2.8	1.1	3.1	33.6	6.7
	2014/08/19	下旬	3.0	1.2	2.8	33.6	7.0
10309	2014/09/05	上旬	1.6	2.3	19.2	34.3	6.9
	2014/09/18	下旬	19.4	ND	13.4	37.3	6.6
10310	2014/10/01	上旬	ND	ND	1.9	32.2	7.2
	2014/10/16	下旬	6.5	1.3	3.8	29.4	7.2
10311	2014/11/03	上旬	2.5	ND	3.6	27.4	7.7
	2014/11/18	下旬	2.2	ND	5.5	26.4	6.9
10312	2014/12/04	上旬	5.6	ND	3.9	26.1	7.5
	2014/12/16	下旬	ND	ND	ND	21.3	7.6