

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH —
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10401	2015/01/05	上旬	ND	ND	ND	19.9	7.7
	2015/01/20	下旬	2.0	ND	2.4	23.2	7.3
10402	2015/02/04	上旬	ND	ND	1.9	25.4	7.8
	2015/02/24	下旬	ND	ND	2.2	32.1	7.8
10403	2015/03/04	上旬	ND	1.4	2.6	23.0	7.2
	2015/03/16	下旬	4.5	ND	3.3	22.5	7.0
10404	2015/04/01	上旬	ND	ND	ND	22.2	7.2
	2015/04/16	下旬	2.1	ND	1.9	22.9	7.1
10405	2015/05/04	上旬	2.0	2.3	6.3	28.2	7.0
	2015/05/19	下旬	ND	ND	1.9	27.4	7.1
10406	2015/06/03	上旬	ND	ND	ND	29.3	7.6
	2015/06/16	下旬	ND	ND	1.7	30.7	7.0
10407	2015/07/03	上旬	1.6	1.2	2.3	32.7	7.5
	2015/07/16	下旬	1.8	1.1	2.0	31.3	7.1
10408	2015/08/03	上旬	2.0	1.6	3.8	33.2	7.5
	2015/08/17	下旬	1.2	ND	2.7	30.9	7.2
10409	2015/09/03	上旬	9.7	ND	8.0	30.0	7.2
	2015/09/15	下旬	3.0	ND	3.5	29.3	7.0
10410	2015/10/02	上旬	ND	ND	1.7	28.1	7.1
	2015/10/19	下旬	3.6	ND	4.1	27.6	7.4
10411	2015/11/04	上旬	4.2	ND	5.0	25.4	7.0
	2015/11/18	下旬	3.7	ND	5.2	26.8	7.1
10412	2015/12/02	上旬	4.9	ND	4.2	25.3	7.3
	2015/12/16	下旬	14.4	1.3	6.6	22.9	7.1