

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH —
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10501	2016/01/05	上旬	7.2	ND	3.5	22.4	7.3
	2016/01/21	下旬	2.4	ND	2.3	19.7	7.2
10502	2016/02/02	上旬	8.8	ND	4.5	20.5	7.4
	2016/02/19	下旬	16.6	ND	5.2	20.0	7.3
10503	2016/03/03	上旬	1.0	ND	ND	19.4	7.8
	2016/03/17	下旬	8.1	2.7	5.6	21.4	7.5
10504	2016/04/06	上旬	18.5	1.9	4.0	23.6	7.2
	2016/04/25	下旬	2.2	ND	1.6	25.4	7.2
10505	2016/05/05	上旬	ND	ND	2.5	25.3	7.1
	2016/05/16	下旬	ND	ND	1.5	25.0	7.5
10506	2016/06/02	上旬	4.7	ND	5.0	29.5	7.0
	2016/06/15	下旬	ND	ND	1.8	28.0	7.0
10507	2016/07/05	上旬	7.8	1.6	4.6	32.4	7.4
	2016/07/19	下旬	1.8	ND	1.7	31.4	7.6
10508	2016/08/04	上旬	3.8	ND	3.8	32.6	7.5
	2016/08/17	下旬	3.6	ND	5.4	32.8	7.4
10509	2016/09/01	上旬	5.1	ND	6.9	32.1	7.5
	2016/09/22	下旬	17.1	1.9	7.5	29.7	7.3
10510	2016/10/06	上旬	8.7	ND	5.6	30.4	7.2
	2016/10/20	下旬	16.1	ND	7.1	28.6	7.3
10511	2016/11/03	上旬	2.1	ND	2.7	22.7	7.5
	2016/11/18	下旬	7.3	ND	5.0	26.3	7.5
10512	2016/12/01	上旬	3.0	ND	2.2	23.6	7.3
	2016/12/15	下旬	1.6	1.4	4.4	23.8	7.3