

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH —
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10601	2017/01/05	上旬	3.6	14.3	16.7	24.3	7.3
	2017/01/18	下旬	2.4	ND	2.6	22.3	7.1
10602	2017/02/03	上旬	5.6	1.3	4.7	21.6	7.4
	2017/02/16	下旬	5.8	ND	3.9	20.4	7.6
10603	2017/03/02	上旬	ND	ND	6.1	20.2	7.3
	2017/03/15	下旬	1.6	2.0	3.5	20.3	7.6
10604	2017/04/06	上旬	2.5	1.4	4.6	23.6	7.5
	2017/04/20	下旬	ND	ND	4.0	25.8	7.6
10605	2017/05/04	上旬	7.7	ND	7.3	25.5	7.4
	2017/05/16	下旬	ND	ND	17.3	26.9	7.6
10606	2017/06/02	上旬	2.4	ND	1.6	25.8	7.3
	2017/06/15	下旬	1.6	3.6	6.2	29.6	7.2
10607	2017/07/06	上旬	1.9	2.1	3.0	32.3	7.5
	2017/07/25	下旬	ND	ND	2.8	32.7	7.4
10608	2017/08/01	上旬	3.0	ND	1.9	32.8	7.5
	2017/08/17	下旬	3.9	2.8	6.8	33.4	7.4
10609	2017/09/04	上旬	ND	ND	2.4	32.3	7.6
	2017/09/20	下旬	ND	ND	ND	30.5	7.8
10610	2017/10/05	上旬	1.6	ND	1.8	31.4	7.6
	2017/10/19	下旬	1.6	ND	6.5	29.8	7.1
10611	2017/11/01	上旬	ND	ND	5.1	26.2	7.7
	2017/11/16	下旬	5.5	ND	7.6	26.1	7.6
10612	2017/12/01	上旬	1.2	ND	5.0	23.7	7.5