

基隆市天外天垃圾資源回收(焚化)廠
廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10801	51.3	49.0	53.8	53.5	52.4	44.2	48.4	49.1
10802	47.7	47.0	45.6	45.2	45.9	45.3	46.6	44.1
10803	47.3	50.0	46.2	44.5	47.7	48.7	47.5	47.2
10804	51.7	53.9	53.2	46.9	51.9	54.7	53.8	50.8
10805	50.2	55.1	54.1	48.4	50.3	50.5	50.5	49.2
10806	48.1	53.3	47.4	47.1	47.6	55.8	50.4	48.2
10807	46.1	52.3	49.9	47.3	50.0	50.6	50.5	46.2
10808	53.7	54.5	54.1	53.7	50.0	51.3	50.5	50.1
10809	47.8	53.2	49.8	45.8	47.9	50.8	46.1	46.0
10810	48.4	53.2	49.5	45.0	46.3	49.1	48.0	44.2
10811	47.8	48.3	47.9	47.9	51.7	52.7	52.5	51.8
10812	46.6	49.3	47.1	46.2	46.0	49.3	47.1	43.9