

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH -
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10801	2019/01/03	上旬	1.5	ND	2.9	21.2	7.2
	2019/01/17	下旬	1.4	2.5	4.3	23.1	7.0
10802	2019/02/14	上旬	2.0	ND	4.2	22.1	7.3
	2019/02/20	下旬	1.0	ND	4.5	21.8	7.6
10803	2019/03/07	上旬	2.0	ND	3.6	21.3	7.4
	2019/03/21	下旬	1.4	3.1	4.1	24.1	7.2
10804	2019/04/02	上旬	1.6	3.0	3.5	23.4	7.1
	2019/04/18	下旬	ND	1.6	2.9	26.2	7.4
10805	2019/05/02	上旬	ND	ND	2.0	27.5	7.4
	2019/05/16	下旬	14.4	ND	9.1	27.3	7.4
10806	2019/06/04	上旬	ND	1.3	4.8	28.1	7.0
	2019/06/20	下旬	3.2	ND	5.2	30.4	7.1
10807	2019/07/03	上旬	1.4	2.3	6.8	30.6	7.6
	2019/07/18	下旬	2.1	ND	5.0	32.2	6.8
10808	2019/08/05	上旬	2.4	3.3	10.1	32.5	6.5
	2019/08/22	下旬	1.2	1.8	3.2	31.8	7.2
10809	2019/09/03	上旬	1.6	1.5	4.7	32.4	6.6
	2019/09/19	下旬	ND	ND	2.4	30.8	7.4
10810	2019/10/03	上旬	ND	ND	2.0	28.8	7.0
	2019/10/17	下旬	ND	ND	ND	28.5	7.2
10811	2019/11/07	上旬	1.6	1.2	13.4	27.7	7.4
	2019/11/21	下旬	ND	ND	6.7	25.2	8.0
10812	2019/12/05	上旬	ND	ND	2.5	23.0	7.0
	2019/12/16	下旬	ND	1.3	4.0	23.5	6.9