

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS mg/L	生化需氧量 BOD mg/L	化學需氧量 COD mg/L	溫度 ℃	pH -
偵測極限			1	1	0.90	-	-
保證值			20	20	50	-	6~9
10901	2020/01/02	上旬	6.9	ND	4.2	23.2	7.0
	2020/01/16	下旬	12.1	ND	4.9	22.3	7.0
10902	2020/02/06	上旬	3.2	ND	3.1	22.7	6.8
	2020/02/17	下旬	5.1	ND	4.3	26.0	6.5
10903	2020/03/05	上旬	2.2	ND	3.9	25.4	6.7
	2020/03/16	下旬	1.2	2.6	4.7	25.8	6.4
10904	2020/04/09	上旬	6.9	ND	3.1	24.4	7.4
	2020/04/23	下旬	ND	ND	ND	23.8	7.5
10905	2020/05/07	上旬	1.2	ND	ND	26.8	7.5
	2020/05/18	下旬	1.4	1.2	2.4	27.6	8.4
10906	2020/06/04	上旬	7.6	ND	6.9	28.6	7.4
	2020/06/16	下旬	4.0	ND	4.2	31.2	7.3
10907	2020/07/02	上旬	2.8	1.3	4.4	33.1	7.4
	2020/07/16	下旬	4.4	ND	3.4	34.0	7.0
10908	2020/08/06	上旬	2.5	ND	3.7	33.1	7.2
	2020/08/17	下旬	1.6	5.9	5.9	33.9	7.3
10909	2020/09/03	上旬	1.4	ND	7.1	32.6	7.1
	2020/09/17	下旬	1.3	ND	2.6	31.2	7.5
10910	2020/10/06	上旬	1.4	ND	4.1	30.6	7.1
	2020/10/15	下旬	ND	ND	1.7	29.0	7.2
10911	2020/11/05	上旬	2.0	ND	3.2	27.6	7.9
	2020/11/19	下旬	ND	ND	ND	27.9	7.1
10912	2020/12/03	上旬	2.0	ND	2.0	23.9	6.6
	2020/12/17	下旬	2.4	ND	2.3	22.8	7.3