

基隆市天外天垃圾資源回收(焚化)廠
廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值 單位:dB(A)	65	70	65	55	65	70	65	55
10901	46.7	52.9	47.7	45.6	46.2	50.5	47.2	45.1
10902	49.0	51.6	47.8	45.6	49.5	50.6	47.6	44.7
10903	46.5	50.0	46.8	45.7	45.9	47.2	45.7	45.2
10904	43.4	45.9	44.3	42.7	42.5	45.2	44.7	41.7
10905	41.9	47.3	44.1	41.7	42.0	46.6	42.1	40.7
10906	54.7	56.8	55.1	52.5	54.0	56.0	55.0	52.2
10907	53.4	54.0	53.1	50.7	51.8	54.6	52.6	50.9
10908	46.3	47.5	49.3	45.1	46.6	46.6	48.0	45.6
10909	48.9	49.9	46.4	48.4	46.0	49.5	45.9	47.9
10910	51.3	53.0	52.8	45.2	51.4	52.3	52.1	48.7
10911	52.1	55.6	56.4	48.6	48.7	54.6	54.5	47.8
10912	47.7	50.8	48.7	47.9	47.1	50.4	49.0	48.4