

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
11101	48.6	55.2	49.3	51.3	51.0	52.1	47.7	51.2
11102	45.5	55.9	47.0	45.5	47.8	51.2	45.8	47.8
11103	47.7	52.3	48.3	45.2	52.7	53.5	46.4	49.6
11104	51.8	58.5	49.6	49.0	54.3	52.1	53.4	47.7
11105	48.8	54.7	53.9	49.3	52.8	52.1	50.1	50.6
11106	57.7	53.2	58.1	48.5	57.4	57.8	60.1	53.9
11107	55.2	56.2	52.5	54.6	56.2	56.2	56.9	54.0
11108	54.0	56.3	51.1	51.0	52.5	53.1	50.3	52.1
11109	53.2	57.4	54.7	53.9	52.8	57.0	51.4	54.4
11110	53.2	64.6	58.6	54.2	47.7	61.3	51.0	47.2
11111	50.9	56.9	49.7	51.6	54.3	56.4	51.1	54.0
11112	49.6	52.6	52.4	48.8	58.0	56.2	49.8	48.0