

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
11101	2022/01/06	上旬	6.0	ND	ND	23.4	6.6
	2022/01/17	下旬	3.2	ND	4.3	22.6	7.5
11102	2022/02/10	上旬	6.7	ND	3.9	21.9	7.6
	2022/02/21	下旬	ND	ND	ND	18.6	7.0
11103	2022/03/03	上旬	5.5	ND	2.8	23.2	7.0
	2022/03/16	下旬	1.4	ND	10.6	26.8	7.0
11104	2022/04/07	上旬	2.2	ND	ND	22.5	7.2
	2022/04/14	下旬	1.9	ND	3.4	24.3	7.0
11105	2022/05/05	上旬	2.6	1.0	9.1	26.3	7.2
	2022/05/16	下旬	1.9	ND	ND	24.7	7.2
11106	2022/06/01	上旬	ND	ND	ND	26.4	7.4
	2022/06/23	下旬	5.2	ND	4.4	29.8	7.0
11107	2022/07/07	上旬	3.4	ND	7.0	30.8	7.1
	2022/07/18	下旬	6.2	ND	4.5	31.9	7.3
11108	2022/08/04	上旬	3.7	ND	5.1	32.5	7.7
	2022/08/16	下旬	2.6	ND	3.1	31.2	7.5
11109	2022/09/01	上旬	3.7	ND	4.9	31.3	7.2
	2022/09/15	下旬	1.3	ND	3.0	29.6	7.4
11110	2022/10/06	上旬	3.9	ND	5.2	30.8	7.1
	2022/10/17	下旬	5.6	ND	5.6	28.2	6.9
11111	2022/11/03	上旬	3.4	ND	3.1	26.4	7.2
	2022/11/17	下旬	11.2	ND	5.6	28.5	7.1
11112	2022/12/01	上旬	3.9	ND	2.3	26.2	6.9
	2022/12/19	下旬	2.0	ND	3.2	21.6	7.0