

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值	65	70	65	55	65	70	65	55
11201	43.3	55.5	49.1	43.5	51.7	53.4	46.8	51.6
11202	51.7	53.5	50.6	45.8	56.0	54.9	50.7	49.1
11203	46.2	57.4	49.7	44.7	52.7	45.7	54.0	52.8
11204	50.8	52.2	46.2	48.4	58.5	52.6	47.1	54.7
11205	51.8	55.3	53.2	48.3	51.0	51.2	49.8	52.9
11206	60.1	56.9	55.0	51.5	62.7	57.8	50.7	52.9
11207	52.4	54.3	50.5	52.0	52.8	53.3	49.3	52.8
11208	54.7	54.8	52.9	54.6	53.8	53.2	50.7	52.7
11209	55.2	59.6	54.7	54.1	54.9	55.6	48.5	53.5
11210	56.7	58.1	59.1	54.4	53.3	54.2	58.9	52.5
11211	51.3	56.8	53.4	51.7	53.1	54.7	49.2	53.3
11212	44.9	52.9	48.4	44.5	52.5	51.5	47.3	51.4