

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
202301	2023/01/01	上旬	1.3	ND	2.9	21.6	6.7
	2023/01/30	下旬	6.2	ND	4.8	26.1	6.4
202302	2023/02/01	上旬	1.7	ND	1.9	22.2	6.4
	2023/02/16	下旬	ND	ND	1.5	22.4	6.4
202303	2023/03/02	上旬	2.2	ND	1.3	21.8	6.6
	2023/03/16	下旬	2.1	ND	4.8	23.7	6.7
202304	2023/04/06	上旬	2.6	ND	1.9	25.4	7.3
	2023/04/17	下旬	1.6	ND	3.5	27.8	6.4
202305	2023/05/04	上旬	ND	ND	4.8	29.4	6.3
	2023/05/18	下旬	1.3	ND	2.6	28.8	6.9
202306	2023/06/02	上旬	4.9	ND	8.3	31.5	7.1
	2023/06/15	下旬	3.2	ND	4.0	31.5	6.7
202307	2023/07/06	上旬	11.7	ND	6.9	34.6	6.9
	2023/07/18	下旬	5.6	ND	8.2	35.6	7.0
202308	2023/08/04	上旬	ND	ND	3.4	33.5	6.4
	2023/08/17	下旬	ND	ND	3.8	33.9	7.3
202309	2023/09/07	上旬	1.0	ND	2.1	34.0	6.9
	2023/09/21	下旬	9.2	ND	6.3	30.8	7.6
202310	2023/10/05	上旬	12.9	ND	6.6	31.5	7.2
	2023/10/16	下旬	2.2	ND	1.7	29.0	6.9
202311	2023/11/02	上旬	ND	ND	12.9	33.4	7.4
	2023/11/16	下旬	3.4	ND	3.2	28.9	6.8
202312	2023/12/07	上旬	1.8	ND	5.1	27.2	6.6
	2023/12/18	下旬	3.0	ND	3.2	24.4	7.1