

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位:dB(A)

| 項目<br>月份 | 廠區周界-1(大門警衛室後方) |      |      |      | 廠區周界-2(管理大樓大門前方) |      |      |      |
|----------|-----------------|------|------|------|------------------|------|------|------|
|          | 早               | 日間   | 晚    | 夜間   | 早                | 日間   | 晚    | 夜間   |
| 保證值      | 65              | 70   | 65   | 55   | 65               | 70   | 65   | 55   |
| 11301    | 45.6            | 53.8 | 49.9 | 44.2 | 53.9             | 54.1 | 51.4 | 53.9 |
| 11302    | 49.9            | 53.2 | 51.5 | 49.2 | 51.7             | 52.8 | 54.3 | 51.4 |
| 11303    | 50.3            | 57.1 | 52.1 | 50.6 | 53.0             | 53.5 | 49.2 | 54.4 |
| 11304    | 53.9            | 53.4 | 48.4 | 53.4 | 55.5             | 50.5 | 49.3 | 49.5 |
| 11305    | 51.6            | 55.7 | 52.9 | 47.4 | 52.9             | 60.2 | 48.2 | 50.5 |
| 11306    | 58.6            | 58.1 | 51.8 | 52.8 | 58.3             | 53.8 | 49.7 | 54.7 |
| 11307    | 51.9            | 57.4 | 51.0 | 54.8 | 52.9             | 52.9 | 47.9 | 52.5 |
| 11308    | 54.1            | 55.0 | 51.5 | 53.9 | 50.9             | 52.7 | 47.2 | 50.4 |
| 11309    | 51.2            | 49.6 | 49.7 | 49.6 | 51.8             | 52.1 | 49.4 | 52.2 |
| 11310    | 54.2            | 56.2 | 51.3 | 53.7 | 51.2             | 52.4 | 47.6 | 51.4 |
| 11311    | 51.1            | 60.1 | 54.7 | 49.5 | 52.7             | 53.8 | 54.6 | 54.5 |
| 11312    | 50.1            | 56.5 | 50.1 | 49.7 | 50.9             | 51.6 | 46.8 | 50.4 |