

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
11301	2024/01/04	上旬	10.1	1.4	16.8	26.4	6.0
	2024/01/18	下旬	13.2	ND	6.0	23.8	6.7
11302	2024/02/01	上旬	8.6	ND	4.8	22.1	7.0
	2024/02/16	下旬	2.0	ND	6.6	21.0	6.6
11303	2024/03/07	上旬	3.8	ND	6.7	26.9	6.1
	2024/03/21	下旬	3.0	ND	3.6	23.7	7.2
11304	2024/04/02	上旬	1.7	ND	7.9	27.9	7.3
	2024/04/18	下旬	ND	ND	5.0	27.4	7.4
11305	2024/05/02	上旬	1.2	ND	3.5	30.0	7.1
	2024/05/16	下旬	ND	ND	3.7	27.7	7.4
11306	2024/06/06	上旬	2.0	ND	6.2	27.7	7.2
	2024/06/17	下旬	ND	ND	2.5	28.9	7.8
11307	2024/07/04	上旬	3.2	ND	9.1	32.9	7.3
	2024/07/16	下旬	ND	ND	3.2	33.2	7.5
11308	2024/08/01	上旬	ND	ND	2.9	31.4	7.3
	2024/08/19	下旬	2.0	ND	5.5	32.6	7.0
11309	2024/09/05	上旬	1.4	ND	2.7	33.0	7.4
	2024/09/18	下旬	1.2	ND	3.6	31.6	7.5
11310	2024/10/06	上旬	2.6	ND	2.9	29.0	7.1
	2024/10/21	下旬	1.4	ND	3.3	28.9	6.9
11311	2024/11/07	上旬	1.5	ND	3.6	26.2	7.0
	2024/11/19	下旬	ND	1.8	3.2	26.1	7.0
11312	2024/12/05	上旬	1.4	ND	3.4	22.8	7.1
	2024/12/16	下旬	1.6	ND	ND	20.3	7.2