

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
11401	2025/01/02	上旬	5.2	ND	7.4	20.6	7.1
	2025/01/16	下旬	4.6	ND	4.7	19.1	7.0
11402	2025/02/07	上旬	ND	1.0	7.8	19.2	7.0
	2025/02/20	下旬	ND	ND	ND	20.0	7.2
11403	2025/03/06	上旬	ND	ND	2.9	21.6	6.8
	2025/03/18	下旬	ND	ND	3.4	21.0	7.2
11404	2025/04/10	上旬	ND	ND	2.5	22.2	7.0
	2025/04/16	下旬	1.0	ND	2.6	23.7	7.0
11405	2025/05/08	上旬	1.0	ND	5.1	26.3	7.0
	2025/05/15	下旬	ND	ND	3.3	26.6	7.0
11406	2025/06/05	上旬	ND	ND	5.9	27.0	7.0
	2025/06/16	下旬	ND	ND	2.0	29.0	7.2