

基隆市天外天垃圾資源回收(焚化)廠 無機廢水水質分析表

申報月份	採樣日期	項目	無機廢水															
			化學需氧量 COD	懸浮固體 SS	銀 Ag	銅 Cu	鋅 Zn	總鉻 Tot-Cr	六價鉻 Cr6+	溶解性鐵 Fe	溶解性錳 Mn	鉛 Pb	鎘 Cd	有機汞 Org-Hg	總汞 Tot-Hg	鎳 Ni	溫度	pH
			mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	℃
偵測極限			0.90	1.0	0.016	0.018	0.0092	0.020	0.0010	0.070	0.014	0.15	0.014	-	0.000085	0.030	-	-
方法偵測極限			1.50	1.0	0.00022	0.00053	0.0011	0.000	0.0009	0.005	0.0019	0.0024	0.00019	0.000084	0.000084	0.001	-	-
保證值			50mg/L	20 mg/l	0.5 mg/l	3.0 mg/l	5.0 mg/l	2.0 mg/l	0.5 mg/l	5.0 mg/l	5.0 mg/l	0.5 mg/l	0.03 mg/l	不得檢出	0.005 mg/l	1.0 mg/l	-	6~9
11401	2025/01/02	上旬	4.5	4.6	<0.002	0.006	0.029	0.020	<0.01	0.104	<0.010	0.013	ND	ND	ND	ND	20.9	7.1
	2025/01/16	下旬	2.7	3.1	<0.002	0.004	0.023	0.003	ND	0.066	<0.010	ND	ND	ND	ND	ND	18.0	7.1
11402	2025/02/07	上旬	4.8	2.7	ND	0.003	0.010	0.005	<0.01	0.070	<0.010	<0.005	ND	ND	ND	ND	19.1	7.1
	2025/02/20	下旬	ND	2.0	ND	<0.002	0.009	<0.002	ND	0.053	<0.010	ND	ND	ND	ND	ND	20.0	7.2
11403	2025/03/06	上旬	2.6	1.1	ND	<0.002	0.006	ND	ND	0.041	<0.010	ND	ND	ND	ND	ND	20.9	7.1
	2025/03/18	下旬	1.8	1.2	ND	<0.002	0.004	ND	<0.01	0.049	<0.010	ND	ND	ND	ND	ND	20.5	7.3
11404	2025/04/10	上旬	ND	2.0	ND	<0.002	0.006	<0.002	<0.01	0.058	<0.010	ND	ND	ND	ND	ND	22.2	7.3
	2025/04/16	下旬	5.3	1.7	ND	<0.002	0.005	ND	ND	0.063	<0.010	ND	ND	ND	ND	ND	23.6	7.3
11405	2025/05/08	上旬	4.5	1.8	ND	<0.002	0.011	ND	<0.01	0.058	<0.010	ND	ND	ND	ND	ND	26.2	7.4
	2025/05/15	下旬	ND	1.6	ND	<0.002	0.010	<0.002	ND	0.066	<0.010	ND	ND	ND	ND	ND	26.4	7.3
11406	2025/06/05	上旬	4.9	4.4	ND	<0.002	0.013	<0.002	ND	0.107	<0.010	ND	ND	ND	ND	ND	26.8	7.2
	2025/06/16	下旬	3.1	2.6	ND	0.003	0.010	<0.002	ND	0.081	0.012	ND	ND	ND	ND	ND	29.0	7.4