

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位: dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值	65	70	65	55	65	70	65	55
11301	45.6	53.8	49.9	44.2	53.9	54.1	51.4	53.9
11302	49.9	53.2	51.5	49.2	51.7	52.8	54.3	51.4
11303	50.3	57.1	52.1	50.6	53.0	53.5	49.2	54.4
11304	53.9	53.4	48.4	53.4	55.5	50.5	49.3	49.5
11305	51.6	55.7	52.9	47.4	52.9	60.2	48.2	50.5
11306	58.6	58.1	51.8	52.8	58.3	53.8	49.7	54.7
11307	51.9	57.4	51.0	54.8	52.9	52.9	47.9	52.5
11308	54.1	55.0	51.5	53.9	50.9	52.7	47.2	50.4
11309	51.2	49.6	49.7	49.6	51.8	52.1	49.4	52.2
11310	54.2	56.2	51.3	53.7	51.2	52.4	47.6	51.4
11311	51.1	60.1	54.7	49.5	52.7	53.8	54.6	54.5
11312	50.1	56.5	50.1	49.7	50.9	51.6	46.8	50.4
11401	49.7	57.3	50.2	49.9	51.3	52.9	46.2	51.1
11402	51.9	59.1	49.6	52.5	49.9	59.5	50.9	53.7
11403	49.6	58.2	57.9	50.0	50.7	51.3	57.9	50.8
11404	49.3	52.3	51.2	49.6	49.4	52.0	49.7	49.7
11405	53.9	58.8	52.2	50.0	50.3	52.4	50.7	49.5
11406	53.2	64.7	53.4	52.9	53.2	57.3	51.4	52.7
11407	58.8	66.6	49.6	51.3	59.4	59.3	47.9	51.7
11408	49.6	62.1	51.2	49.8	51.2	54.8	48.6	51.3
11409	51.6	58.3	49.7	51.5	52.4	53.9	48.6	52.6
11410	48.2	52.5	49.0	48.3	54.5	55.1	54.6	54.5
11411	50.9	66.5	52.3	51.1	55.5	63.7	55.5	54.5