

基隆市天外天垃圾資源回收(焚化)廠

廠區周界噪音監測結果

單位: dB(A)

項目 月份	廠區周界-1(大門警衛室後方)				廠區周界-2(管理大樓大門前方)			
	早	日間	晚	夜間	早	日間	晚	夜間
保證值	65	70	65	55	65	70	65	55
11401	49.7	57.3	50.2	49.9	51.3	52.9	46.2	51.1
11402	51.9	59.1	49.6	52.5	49.9	59.5	50.9	53.7
11403	49.6	58.2	57.9	50.0	50.7	51.3	57.9	50.8
11404	49.3	52.3	51.2	49.6	49.4	52.0	49.7	49.7
11405	53.9	58.8	52.2	50.0	50.3	52.4	50.7	49.5
11406	53.2	64.7	53.4	52.9	53.2	57.3	51.4	52.7
11407	58.8	66.6	49.6	51.3	59.4	59.3	47.9	51.7
11408	49.6	62.1	51.2	49.8	51.2	54.8	48.6	51.3
11409	51.6	58.3	49.7	51.5	52.4	53.9	48.6	52.6
11410	48.2	52.5	49.0	48.3	54.5	55.1	54.6	54.5
11411	50.9	66.5	52.3	51.1	55.5	63.7	55.5	54.5
11412	48.4	63.8	55.6	48.6	54.8	55.8	58.3	54.7