

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
11401	2025/01/02	上旬	5.2	ND	7.4	20.6	7.1
	2025/01/16	下旬	4.6	ND	4.7	19.1	7.0
11402	2025/02/07	上旬	ND	1.0	7.8	19.2	7.0
	2025/02/20	下旬	ND	ND	ND	20.0	7.2
11403	2025/03/06	上旬	ND	ND	2.9	21.6	6.8
	2025/03/18	下旬	ND	ND	3.4	21.0	7.2
11404	2025/04/10	上旬	ND	ND	2.5	22.2	7.0
	2025/04/16	下旬	1.0	ND	2.6	23.7	7.0
11405	2025/05/08	上旬	1.0	ND	5.1	26.3	7.0
	2025/05/15	下旬	ND	ND	3.3	26.6	7.0
11406	2025/06/05	上旬	ND	ND	5.9	27.0	7.0
	2025/06/16	下旬	ND	ND	2.0	29.0	7.2
11407	2025/07/03	上旬	1.2	ND	2.6	31.8	7.2
	2025/07/15	下旬	ND	ND	4.3	30.9	7.0
11408	2025/08/08	上旬	1.6	ND	4.0	30.9	6.7
	2025/08/18	下旬	1.8	ND	5.7	30.8	6.9
11409	2025/09/04	上旬	ND	2.7	ND	32.2	7.1
	2025/09/18	下旬	4.0	2.8	16.0	32.8	7.6
11410	2025/10/02	上旬	ND	ND	4.0	31.6	7.0
	2025/10/20	下旬	ND	0.4	<10.0	30.9	7.0
11411	2025/11/06	上旬	ND	0.3	4.0	26.2	7.0
	2025/11/17	下旬	ND	<0.1	<10.0	25.8	7.0
11412	2025/12/04	上旬	ND	0.3	4.9	24.0	7.1
	2025/12/17	下旬	ND	0.4	<10.0	23.6	7.0