

基隆市天外天垃圾資源回收(焚化)廠 無機廢水水質分析表

申報月份	採樣日期	項目	無機廢水															
			化學需氧量 COD	懸浮固體 SS	銀 Ag	銅 Cu	鋅 Zn	總鉻 Tot-Cr	六價鉻 Cr6+	溶解性鐵 Fe	溶解性錳 Mn	鉛 Pb	鎘 Cd	有機汞 Org-Hg	總汞 Tot-Hg	鎳 Ni	溫度	pH
			mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	℃	-
偵測極限			0.90	1.0	0.016	0.018	0.0092	0.020	0.0010	0.070	0.014	0.15	0.014	-	0.000085	0.030	-	-
方法偵測極限			1.50	1.0	0.00022	0.00053	0.0011	0.000	0.0009	0.005	0.0019	0.0024	0.00019	0.000084	0.000084	0.001	-	-
保證值			50mg/L	20 mg/l	0.5 mg/l	3.0 mg/l	5.0 mg/l	2.0 mg/l	0.5 mg/l	5.0 mg/l	5.0 mg/l	0.5 mg/l	0.03 mg/l	不得檢出	0.005 mg/l	1.0 mg/l	-	6~9
11501	2026/01/08	上旬	2.6	2.6	ND	<0.002	0.016	<0.002	ND	0.111	<0.010	ND	ND	ND	ND	ND	19.6	7.4
	2026/01/22	下旬	<10.0	1.3	ND	<0.002	0.008	<0.002	ND	0.068	<0.010	ND	ND	ND	ND	ND	19.6	7.3