

基隆市天外天垃圾資源回收(焚化)廠 有機廢水水質分析表

申報月份	採樣日期	項目	有機廢水				
			懸浮固體 SS	生化需氧量 BOD	化學需氧量 COD	溫度	pH
			mg/L	mg/L	mg/L	℃	—
偵測極限			1	1	0.90	-	-
方法偵測極限			1	1	1.50	-	-
保證值			20	20	50	-	6~9
11501	2026/01/08	上旬	4.2	2.6	8.9	20.2	7.2
	2026/01/22	下旬	ND	<0.1	<10.0	19.6	7.1
11502	2026/02/05	上旬	ND	2.3	4.2	21.4	6.7
	2026/02/23	下旬	2.0	0.2	<10.0	21.2	6.9
11503	2026/03/05	上旬	2.1	<0.1	3.8	22.4	7.0
	2026/03/19	下旬	2.1	0.8	<10.0	21.4	7.0
11504	2026/04/09	上旬	ND	0.4	10.0	24.4	7.2
	2026/04/15	下旬	ND	0.2	4.6	25.6	7.5
11505	2026/05/07	上旬	2.5	0.2	<10.0	25.8	7.3
	2026/05/18	下旬	2.4	0.6	<10.0	25.8	7.1
11506	2026/06/04	上旬	2.2	2.2	18.0	25.8	7.5
	2026/06/17	下旬	1.4	0.8	6.3	27.6	6.8