

基隆市天外天垃圾資源回收(焚化)廠 無機廢水水質分析表

申報月份	採樣日期	項目	無機廢水															
			化學需氧量	懸浮固體	銀	銅	鋅	總鉻	六價鉻	溶解性鐵	溶解性錳	鉛	鎘	有機汞	總汞	鎳	溫度	pH
			COD	SS	Ag	Cu	Zn	Tot-Cr	Cr6+	Fe	Mn	Pb	Cd	Org-Hg	Tot-Hg	Ni	℃	—
			mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	℃	—
偵測極限			0.90	1.0	0.016	0.018	0.0092	0.020	0.0010	0.070	0.014	0.15	0.014	-	0.000085	0.030	-	-
方法偵測極限			1.50	1.0	0.00022	0.00053	0.0011	0.000	0.0009	0.005	0.0019	0.0024	0.00019	0.000084	0.000084	0.001	-	-
保證值			50mg/L	20 mg/l	0.5 mg/l	3.0 mg/l	5.0 mg/l	2.0 mg/l	0.5 mg/l	5.0 mg/l	5.0 mg/l	0.5 mg/l	0.03 mg/l	不得檢出	0.005 mg/l	1.0 mg/l	-	6~9
11501	2026/01/08	上旬	2.6	2.6	ND	<0.002	0.016	<0.002	ND	0.111	<0.010	ND	ND	ND	ND	ND	19.6	7.4
	2026/01/22	下旬	<10.0	1.3	ND	<0.002	0.008	<0.002	ND	0.068	<0.010	ND	ND	ND	ND	ND	19.6	7.3
11502	2026/02/05	上旬	4.0	3.8	<0.002	<0.002	0.010	<0.002	<0.01	0.080	<0.010	ND	ND	ND	ND	ND	21.0	6.8
	2026/02/23	下旬	<10.0	2.2	ND	<0.002	0.005	ND	<0.01	0.096	<0.010	ND	ND	ND	ND	ND	21.2	7.3
11503	2026/03/05	上旬	3.2	11.8	ND	<0.002	0.016	<0.002	ND	0.125	<0.010	ND	ND	ND	ND	ND	22.2	7.5
	2026/03/19	下旬	<10.0	2.7	ND	0.004	0.009	0.005	ND	0.068	<0.010	ND	ND	ND	ND	ND	21.6	7.2
11504	2026/04/09	上旬	3.9	1.1	ND	0.004	0.007	<0.002	<0.01	0.056	<0.010	ND	ND	ND	ND	ND	24.1	9.0
	2026/04/14	下旬	1.8	ND	ND	<0.002	0.012	<0.002	ND	0.073	<0.010	ND	ND	ND	ND	ND	25.4	7.7
11505	2026/05/07	上旬	<10.0	ND	ND	<0.002	0.007	<0.002	ND	0.058	<0.010	ND	ND	ND	ND	ND	25.8	7.5
	2026/05/18	下旬	<10.0	5.9	ND	0.003	0.024	0.003	<0.01	0.175	0.014	ND	ND	ND	ND	ND	26.0	7.4
11506	2026/06/04	上旬	12.8	4.4	ND	0.004	0.015	<0.002	<0.01	0.032	<0.010	<0.005	ND	ND	ND	ND	29.5	7.4
	2026/06/17	下旬	2.9	2	ND	<0.002	0.012	ND	<0.01	0.114	<0.010	ND	ND	<0.0004	<0.0004	ND	27.3	7.2